



TEST REPORT

DATE: 03-07-2018

Page 1 of 1

TEST NUMBER: 0244992

CLIENT	Urban Surfaces
---------------	----------------

TEST METHOD CONDUCTED	ASTM F410 Standard Test Method for Wear Layer Thickness of Resilient Floor Coverings by Optical Measurement
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Sound Tec
CONSTRUCTION	Floor Plank

GENERAL PRINCIPLE

The thickness of the wear layer of resilient non-textile floor coverings is determined by microscopic optical measurement. The specimen is examined in three areas and measurements are made on the outer most layer of the composite material. The measurements are recorded to the .001 inch and averaged.

TEST RESULTS

	THICKNESS	
SPECIMEN 1	0.024 inch	0.60 mm
SPECIMEN 2	0.024 inch	0.61 mm
SPECIMEN 3	0.024 inch	0.62 mm
SPECIMEN 4	0.024 inch	0.61 mm
SPECIMEN 5	0.024 inch	0.60 mm
AVERAGE TOTAL THICKNESS	0.024 Inch	0.61 mm

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.