



TEST REPORT

DATE: 01-11-2018

Page 1 of 1

TEST NUMBER: 0243052

CLIENT	Urban Surfaces
---------------	----------------

TEST METHOD CONDUCTED	ASTM F386 Standard Test Method for Thickness of Resilient Flooring Materials Having Flat Surfaces
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Alamo Click
CONSTRUCTION	Floating Floor Plank

GENERAL PRINCIPLE

The total thickness of a resilient flooring material is determined through measurements made using a .250 inch presser foot and a dial micrometer. The average of 5 total measurements is reported as the average total thickness.

TEST RESULTS

		THICKNESS
	SPECIMEN 1	0.240 Inch
	SPECIMEN 2	0.240 Inch
	SPECIMEN 3	0.239 Inch
	SPECIMEN 4	0.242 Inch
	SPECIMEN 5	0.241 Inch
AVERAGE TOTAL THICKNESS		0.240 Inch

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.